

BLANK PAGE



भारतीय मानक

जलदृढ़ी सीमेंट के लिए भौतिक परीक्षण की पद्धतियाँ

भाग 15 आई छन्नी द्वारा बारीकी ज्ञात करना

Indian Standard

METHODS OF PHYSICAL TESTS FOR HYDRAULIC CEMENT

PART 15 DETERMINATION OF FINENESS BY WET SIEVING

Second Reprint OCTOBER 1997

UDC 66:942:620:168:32

© BIS 1991

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

FOREWORD

This Indian Standard was adopted by the Bureau of Indian Standards, after the draft finalized by the Cement and Concrete Sectional Committee had been approved by the Civil Engineering Division Council.

Standard methods of testing cement are essential adjunct to the cement specifications. This standard in different parts, lays down the test procedures to evaluate the physical properties of different types of hydraulic cement. This part covers determination of fineness of cement by wet sieving. The procedures for conducting chemical tests of hydraulic cement are covered in IS 4032 series 'Methods of chemical analysis of hydraulic cement'.

Determination of fineness by wet sieving is required mainly for masonry cement, but the same method shall be applied when any manufacturer or user wants to determine fineness of any other cement for any other specific reason.

The composition of the technical committee responsible for the formulation of this standard is given in Annex A.

In reporting the results of a test or analysis made in accordance with this standard, if the final value, observed or calculated, is to be rounded off, it shall be done in accordance with IS 2: 1960 'Rules for rounding off numerical values (revised)'.

Indian Standard

METHODS OF PHYSICAL TESTS FOR HYDRAULIC CEMENT

PART 15 DETERMINATION OF FINENESS BY WET SIEVING

1 SCOPE

This standard (Part 15) covers the procedure for determining the fineness of cement by wet sieving as represented by the mass of the residue left on a standard 45-micron IS Sieve.

2 REFERENCES

The Indian Standards listed below are necessary adjuncts to this standard.

IS No. Title

3535: 1986 Methods of sampling hydra-

ulic cements (first revision)

460 (Part 1): 1985 Specification for test sieves: Part 1 Wire cloth test

sieves (third revision)

3 SAMPLING AND SELECTION OF TEST SAMPLES

The samples of the cement shall be taken in accordance with the requirements of IS 3535: 1986 and the relevant standard specification for the type of cement being tested. The representative sample of the cement selected as above shall be thoroughly mixed before testing.

4 TEMPERATURE

The temperature of the room and the materials shall preferably be maintained at $27 \pm 2^{\circ}$ C.

5 APPARATUS

5.1 Sieve

The sieve frame shall be of non-corrodible material and shall be circular 50 ± 5 mm in diameter. The depth of the sieve from the top of the frame to the cloth shall be 75 ± 5 mm. The frame shall have either side walls 90 ± 5 mm in total height or legs of sufficient length, 120 mm minimum, to allow air circulation beneath the sieve cloth. The sieve frame shall be fitted with 45 micron stainless steel woven wire cloth sieve conforming to IS 460 (Fart 1): 1985. The cloth shall be mounted in the frame without distortion, looseness or wrinkling. For a sieve fabricated by soldering the cloth to the frame, the joint shall be made smooth to prevent the cement from catching in the joints between the sieve cloth and frame. Two piece

sieves shall clamp tightly on the cloth to prevent the cement from catching in the joints between the sieve cloth and the frame.

5.2 Spray Nozzle

The spray nozzle (see Fig. 1) shall be constructed with non-corrodible material and shall be of 17.5 mm inside diameter with a central hole drilled in line with the longitudinal axis, and intermediate row of eight holes drilled 6 mm centre to centre at an angle of 5° from the longitudinal axis, and an outer row of eight holes drilled 11 mm centre to centre at an angle of 10° from the longitudinal axis. All holes shall be of 0.5 mm diameter.

5.3 Pressure Gauge

The pressure gauge shall be of 75 mm minimum diameter and shall be graduated in 0.01 N/mm² increments and shall have a maximum capacity of 0.2 N/mm² with a marking at 0.07 N/mm³. The accuracy at 0.07 N/mm² shall be 0.005 N/mm².

5.4 Balance

Analytical balance capable of reproducing results within 0.000 2 g with an accuracy of ± 0.000 2 g.

NOTE -- Self indicating balance with equivalent accuracy may also be used.

5.5 Standard Weights


5.6 Oven

6 CALIBRATION OF 45 MICRON IS SIEVE


The calibration of the 45 micron sieve shall be made using standard reference material (SRM) from National Council of Cement and Building Materials. Place 1 000 g of the SRM on the clean dry 45 micron sieve and 1 proceed as in 7. The sieve correction factor is the difference between the test residue obtained and the assigned residue value indicated by the electro-formed sheet sieve fineness specified for the standard sample, expressed as a percentage of the test residue. The sieve shall be re-calibrated after every 100 determinations.

Example:

Residue on 45 micron IS Sieve of 14.0 percent SRM sample
Residue for a 1 g sample
Residue on Sieve being calibrated
Difference
Correction $= \frac{0.035 \times 100}{0.105} = +33.3$ percent



SPRAY NOZZLE ASSEMBLY



All dimensions in millimetres.

FIG. 1 SPRAY NOZZLE

7 PROCEDURE

Place 1'000 g of sample of the cement on a clean, dry 45 micron IS Sieve. Wet the sample thoroughly with a gentle stream of water. Remove the sieve from under the nozzle and adjust the pressure on the spray nozzle to $0.07 \pm 0.005 \text{ N/mm}^2$. Return the sieve to its position under the nozzle and wash for 1 min, moving the sieve with a circular motion in a horizontal plane at the rate of one motion per second in the spray. The bottom of the spray nozzle shall extend below the top of the sieve frame by about 12 mm. Immediately upon removing the sieve from the spray, rinse once with 50 ml of distilled water, taking care not to lose any of the residue, and then blot the lower surface gently upon a damp cloth. Dry the sieve and residue in an oven or over a hot plate (see Note), supporting the sieve in such a manner that air may pass freely beneath it. Cool the sieve, brush the residue from the sieve and weigh.

NOTE — Care should be taken not to heat the sieve hot enough to soften the solder.

8 CALCULATION

Calculate the mass of the residue of the cement left on the standard 45 micron IS Sieve to the nearest 0.1 percent as follows:

$$Rc = Rs \times (100+C)$$

where

Rc =corrected residue in percent,

Rs = residue of the sample retained on the 45 micron IS Sieve in g, and

C = sieve correction factor which may be either plus or minus.

Example:

Sieve correction factor, $C = +33^{\circ}3$ percent Residue from sample being tested, Rs = 0.092 g Corrected residue = $0.092 \times (100 + 33.3)$ = 12.3 percent

ANNEX A

(Foreword)

COMPOSITION OF THE TECHNICAL COMMITTEE

Cement and Concrete Sectional Committee, CED 2

Chairman	
----------	--

DR H. C. VISVESVARAYA

Members

SHRI H. BHATTACHARYA

DR A. K. CHATTERJEE

SHRI S. H. SUBRAMANIAN (Alternate)

CHIEF ENGINEER (DESIGNS)

SUPERINTENDING ENGINEER (S & S)

(Alternate)

CHIEF ENGINEER, NAVAGAM DAM

SUPERINTENDING ENGINEER, OCC

(Alternate)

CHIEF ENGINEER (RESEARCH-CUM-

DIRECTOR)

RESEARCH OFFICER (CONCRETE TECHNOLOGY) (Alternate)

DIRECTOR

JOINT DIRECTOR (Alternate)

DIRECTOR (C & MDD) (N & W)
DEPUTY DIRECTOR (C & MDD)
(NW & S) (Alternate)

SHRI K. H. GANGWAL

SHRI V. PATTABHI (Alternate)
SHRI V. K. GHANEKAR

SHRI S. GOPINATH

SHRI R. TAAMILAKARAN (Alternate)

SHRI S. K. GUHA THAKURTA

SHRI S. P. SHANKARANARAYANAN (Alternate)

DR IRSHAD MASOOD

DR MD KHALID (Alternate)

JOINT DIRECTOR, STANDARDS (B&S) (CB-1)

JOINT DIRECTOR STANDARDS (B&S)/

(CB-II) (Alternate)

SHRI N. G. JOSHI

SHRI P. D. KELKAR (Alternate)

SHRI D. K. KANUNGO

SHRI B. R. MEENA (Alternate)

SHRI P. KRISHNAMURTHY

SHRI S. CHAKRAVARTHY (Alternate)

SHRI G. K. MAJUMDAR

SHRI S. O. RANGARI (Alternate)

SHRI P. N. MEHTA

SHRI J. S. SANGANERIA (Alternate)

MEMBER SECRETARY

Director (Civil) (Alternate)

SHRI M. K. MUKHERJEE

SHRI M. K. GHOSH (Alternate)

DR A. K. MULLICK

DR S. C. AHLUWALIA (Alternate)

SHRI NIRMAL SINGH

SHRIS, S. MIGLANI (Alternate)

SHRI R. C. PARATE

LT-COL R. K. SINGH (Alternate)

Representing

In personal capacity (University of Roorkee, Roorkee 247667)

Orissa Cement Limited, New Delhi

The Associated Cement Companies Ltd, Bombay

Central Public Works Department, New Delhi

Sardar Sarovar Narmada Nigam Ltd, Gandhinagar

Irrigation and Power Research Institute, Amritsar

A, P. Engineering Research Laboratories, Hyderabad

Central Water Commission, New Delhi

Hyderabad Industries Limited, Hyderabad

Structural Engineering Research Centre (CSIR), Ghaziabad

The India Cements Limited, Madras

Gannon Dunkerley & Company Limited, Bombay

Central Building Research Institute (CSIR), Roorkee

Research, Designs and Standards Organization (Ministry of

Railways), Lucknow

Indian Hume Pipes Co Limited, Bombay

National Test House, Calcutta

Larsen and Toubro Limited, Bombay

Hospital Services Consultancy Corporation (India) Ltd,

New Delhi

Geological Survey of India, Calcutta

Central Board of Irrigation and Power, New Delhi

Roads Wing Department of Surface Transport (Ministry of

Transport), New Delhi

National Council for Cement and Building Materials, New Delhi

Development Commissioner for Cement Industry (Ministry of Industry)

Engineer-in-Chief's Branch, Army Headquarters

IS 4031 (Part 15): 1991

Momhors

Shri H. S. Pasricha

SHRI Y. R. PHULL

SHRI S. S. SEEHRA (Alternate)

SHRI Y. R. PHULL

SHRI K. B. THANDEVAN (Alternate)

DR M. RAMAIAH

DR A. G. MADHAVA RAO (Alternate)

SHRI G. RAMDAS

REPRESENTATIVE

SHRI A. U. RIJHSINGHANI

SHRI C. S. SHARMA (Alternate)

SHRI J. SEN GUPTA

SHRI A. K. LAL (Alternate)

SHRI T. N. SUBBA RAO

SHRI S. A. REDDI (Alternate)

SUPT. ENGINEER (DESIGNS)

EXECUTIVE ENGINEER (S.M.R. DIVISION)

(Alternate)
Shri S. B. Suri

SHRI N. CHANDRASEKARAN (Alternate)

DR H. C. VISVESVARAYA

SHRI D. C. CHATURVEDI (Alternate)

SHRI G. RAMAN,

Director (Civil Engg)

Representing

Hindustan Prefab Ltd, New Delhi

Central Road Research Institute (CSIR), New Delhi

Indian Roads Congress, New Delhi

Structural Engineering Research Centre (CSIR), Madras

Directorate General of Supplies and Disposals, New Delbi

Builders Association of India, Bombay

Cement Corporation of India, New Delhi

National Buildings Organization, New Delhi

Gammon India Limited, Bombay

Public Works Department, Government of Tamil Nadu

Central Soil and Materials Research Station, New Delhi

The Institution of Engineers (India), Calcutta

Director General, BIS (Ex-officio Member)

Secretary

SHRI N. C. BANDYOPADHYAY

Joint Director (Civil Engg), BIS

Cement, Pozzolana and Cement Additives Subcommittee, CED 2:1

Convener

DR H. C. VISVESVARAYA

Members

SHRI S. K. BANERJEE

SHRI N. G. BASAK

SHRI T. MADNESHWAR (Alternate)

SHRI SOMNATH BANERJEE

Chief Engineer (Research-cum-Director)
Research Officer (CT) (Alternate)

SHRI N. B. DESAI

SHRI J. K. PATEL (Alternate)

DIRECTOR

RESEARCH OFFICER (Alternate)

DIRECTOR (C & MDD II)

DEPUTY DIRECTOR (C & MDD II)

(Alternate)

SHRI R. K. GATTANI

SHRI R. K. VAISHNAVI (Aliernate)

SHRI P. J. JAGUS

DR A. K. CHATTERJEE (Alternate)

JOINT DIRECTOR (MATERIALS)

ASSTT DIRECTOR (PLASTIC) (Alternate)

Joint Director Standards (B & S) (CB-1)

Joint Director, Standards (B&S) (CB-II) (Alternate)

SHRI R. L. KAPOOR

SHRI R. K. DATTA (Alternate)

SHRI W. N. KARODE

SHRI R. KUNJITHAPATTAM

In personal capacity (University of Roorkee, Roorkee 247667)

National Test House, Calcutta

Directorate General of Technical Development, New Delhi

Cement Manufacturers Association, Bombay

Irrigation Department, Government of Punjab

Gujarat Engineering Research Institute, Vadodara

Maharashtra Engineering Research Institute, Nasik

Central Water Commission, New Delhi

Shree Digvijay Cement Co Ltd, Bombay

The Associated Cement Companies Ltd, Bombay

National Buildings Organization, New Delhi

Research, Designs and Standards Organization (Ministry of Railways), Lucknow

Roads Wing, Department of Surface Transport, Ministry of Transport, New Delhi

The Hindustan Construction Co Ltd, Bombay

Chettinad Cement Corporation Ltd, Poliyur, Tamil Nadu

Members

SHRI G. K. MAJUMDAR

DR IRSHAD MASOOD
SHRI K. P. MOHIDEEN
DR A. K. MULLICK
DR (SMT) S. LAXMI (Alternate)

SHRI K. NARANAPPA SHRI D. P. KEWALRAMANI (Alternate)

SHRI NIRMAL SINGH

SHRI S. S. MIGLANI (Alternate)

SHRI Y. R. PHULL
SHRI S. S. SEEHRA (Alternate)

SHRI A. V. RAMANA
DR K. C. NARANG (Alternate)
COL V. K. RAO

SHRI N. S. GALANDE (Alternate)
SHRI S. A. REDDI

SHRI A. U. RIJHSINGHANI
SHRI M. P. SINGH
SUPERINTENDING ENGINEER (D)
SENIOR DEPUTY CHIEF ENGINEER
(GENERAL) (Alternate)

SHRI S. B. SURI SHRI N. CHANDRASEKARAN (Alternate)

SHRI L. SWAROOP
SHRI H. BHATTACHARYA (Alternate)

SHRI V. M. WAD

Representing

Hospital Services Consultancy Corporation (India) Ltd, New Delhi Central Building Research Institute (CSIR), Roorkee

Central Building Research Institute (CSIR), Roorkee Central Warehousing Corporation, New Delhi

National Council for Cement and Building Materials, New Delhi

Central Electricity Authority, New Delhi

Development Commissioner for Cement Industry (Ministry of Industry)

Central Road Research Institute (CSIR), New Delhi

Dalmia Cement (Bharat) Ltd, New Delhi

Engineer-in-Chief's Branch, Army Headquarters

Gammon India Ltd, Bombay Cement Corporation of India Ltd, New Delhi Federation of Mini Cement Plants, New Delhi Public Works Department, Govt of Tamil Nadu

Central Soil and Materials Research Station, New Delhi

Orissa Cement Ltd. New Delhi

Bhilai Steel Plant, Bhilai

Bureau of Indian Standards

BIS is a statutory institution established under the Bureau of Indian Standards Act, 1986 to promote harmonious development of the activities of standardization, marking and quality certification of goods and attending to connected matters in the country.

Copyright

Amend No.

BIS has the copyright of all its publications. No part of these publications may be reproduced in any form without the prior permission in writing of BIS. This does not preclude the free use, in the course of implementing the standard, of necessary details, such as symbols and sizes, type or grade designations. Enquiries relating to copyright be addressed to the Director (Publication), BIS.

Review of Indian Standards

Amendments are issued to standards as the need arises on the basis of comments. Standards are also reviewed periodically; a standard along with amendments is reaffirmed when such review indicates that no changes are needed; if the review indicates that changes are needed, it is taken up for revision. Users of Indian Standards should ascertain that they are in possession of the latest amendments or edition by referring to the latest issue of 'BIS Handbook' and 'Standards Monthly Additions'.

This Indian Standard has been developed from Doc: No. CED 2 (4767)

Date of Issue

PATNA. PUNE. THIRUVANANTHAPURAM.

Amendments Issued Since Publication

	·
BUREAU OF INDIAN STANDARDS	
Headquarters:	
Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002 Telephones: 323 01 31, 323 33 75, 323 94 02	Telegrams: Manaksanstha (Common to all offices)
Regional Offices:	Telephone
Central: Manak Bhavan, 9 Bahadur Shah Zafar Marg NEW DELHI 110002	323 76 17, 323 38 41
Eastern : 1/14 C.I.T. Scheme VII M, V.I.P. Road, Maniktola CALCUTTA 700054	{337 84 99, 337 85 61 337 86 26, 337 91 20
Northern: SCO 335-336, Sector 34-A, CHANDIGARH 160022	$\begin{cases} 60\ 38\ 43\\ 60\ 20\ 25 \end{cases}$
Southern: C.I.T. Campus, IV Cross Road, CHENNAI 600113	{235 02 16, 235 04 42 235 15 19, 235 23 15
Western: Manakalaya, E9 MIDC, Marol, Andheri (East) MUMBAI 400093	{832 92 95, 832 78 58 832 78 91, 832 78 92
Branches: AHMADABAD. BANGALORE. BHOPAL. BHUBANESHWAR. COIMBATORE. FARIDABAD. GHAZIABAD. GUWAHATI. HYDERABAD. JAIPUR. KANPUR. LUCKNOW. NAGPUR.	

Printed by Reprography Unit, BIS, New Delhi

Text Affected