

**From:** "Ferguson, Steve" <SFerguson@ashrae.org>  
**Subject:** FW: FW: California 2008 Standards adopted today  
**Date:** April 28, 2008 9:13:10 AM EDT  
**To:** "Ferguson, Steve" <SFerguson@ashrae.org>, "David Knebel" <davidk@aaon.com>, <sdkenned@southernco.com>, "Nance Lovvorn" <nlovvorn@charter.net>, <bwo@mek.dtu.dk>, <DConover@iccsafe.org>, "Littleton, Jeff" <JLittleton@ashrae.org>, <ahallstrom@mail.ashrae.org>, "Ramspeck, Claire" <CRamspeck@ashrae.org>  
**Cc:** "Andrew Persily" <andrew.persily@nist.gov>, <rhermans@mncee.org>, <gholness@comcast.net>

---

To members of SAC:  
Please see below about the adoption of 62.2 in CA Title 24. This may be useful for the ongoing discussions within SAC.  
Steve

----- Forwarded message from Max Sherman <mhsherman@lbl.gov> -----  
Date: Wed, 23 Apr 2008 14:59:39 -0700  
From: Max Sherman <mhsherman@lbl.gov>  
Reply-To: MHSherman@lbl.gov  
Subject: FW: California 2008 Standards adopted today  
To: Jodi Scott Dunlop <jdunlop@ashrae.org>

Jodi,

2008 CA Title 24 standards were officially adopted today. One of the biggest changes is that ASHRAE Standard 62.2 is now mandatory. A lot of houses will be better ventilated because of that. Don't know if that

is worth some press.

=====  
Max Sherman

Steve Ferguson, Assistant Manager of Standards - Codes  
American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.  
Direct Line: 678-539-1138 Fax: 678-539-2138 eMail: SFerguson@ashrae.org Web: www.ASHRAE.org

Register by May 23 to save on ASHRAE's Annual Meeting June 21-23 in Salt Lake City , where the first High-Performance Building Design Professional certification exam will be given.

P Please consider the environment before printing this e-mail.

-----Original Message-----

From: Bruce A. Wilcox [mailto:bawilcox@inreach.com]  
Sent: Wednesday, April 23, 2008 2:51 PM  
To: MHSherman@lbl.gov; Iain Walker; StevensD@us.panasonic.com; Steve Emmerich  
Subject: California 2008 Standards adopted today

including a mandatory requirement that every new home comply with 62.2 (openable windows not allowed).

One of the staff guys asked me about getting permission to use the materia  
in the users manual for training.

Thanks for your help now and even more in the future.

Bruce

----- End forwarded message -----

--

\*\*\*\*\*  
Andy Persily  
NIST  
100 Bureau Drive, MS8633  
Gaithersburg, MD 20899  
andyp@nist.gov  
301 975-6418  
Fax 975-4409  
\*\*\*\*\*