

**ERRATA SHEET FOR ADDENDUM r TO
ANSI/ASHRAE/IESNA STANDARD 90.1-2007 (I-P edition)
Energy Standard for Buildings Except Low-Rise Residential Buildings**

August 26, 2010

NOTICE: ASHRAE now has a list server for Standing Standards Project Committee 90.1 (SSPC 90.1). Interested parties can now subscribe and unsubscribe to the list server and be automatically notified via e-mail when activities and information related to the Standard and the User's Manual is available. To sign up for the list server please visit **Project Committee List Servers for Standard** on the Technology / Standards section of the ASHRAE website at <http://www.ashrae.org/publications/detail/15620>.

Page(s) Erratum

- 13 Table G3.1.2.9 Baseline Fan Brake Horsepower.** In the second column change “0.00013” to “0.0013” in the equation for brake horsepower of baseline fan motor for Variable Volume Systems 5-8.