

Errata for the 2003 Uniform Mechanical Code™ (5th Printing soft cover)

Chapter 5:

Section 504.5: please revise this section to read, "Environmental air duct exhaust *shall terminate a minimum of three (3) feet (914mm)* from property line *and three (3) feet (914mm)* from openings into the buildings.