

## **Errata for 2006 Uniform Plumbing Code – 9th Printing**

The following is a list of changes that we found after the ninth printing of the 2006 Uniform Plumbing Code. These changes may or may not apply to your code book. However, we do encourage you to check your code book with this list to ensure that all the changes are updated. Thank you.

### Chapter 4

**Table 4-1**            Revise Table 4-1 to show footnote 18.

05/07/09

Table 4-1 continued

## UNIFORM PLUMBING CODE

Type of Building or Occupancy <sup>2</sup>	Water Closets <sup>14</sup> (Fixtures per Person)		Urinals <sup>5,10</sup> (Fixtures per Person)	Lavatories (Fixtures per Person)		Bathtubs or Showers (Fixtures per Person)	Drinking Fountains <sup>3,13,18</sup> (Fixtures per Person)
Office or public buildings	Male 1: 1-100 2: 101-200 3: 201-400 Over 400, add one fixture for each additional 500 males and 1 for each additional 150 females.	Female 3: 1-50 4: 51-100 8: 101-200 11: 201-400	Male 1: 1-100 2: 101-200 3: 201-400 4: 401-600 Over 600, add 1 fixture for each additional 300 males.	Male 1: 1-200 2: 201-400 3: 401-750 Over 750, add one fixture for each additional 500 persons.	Female 1: 1-200 2: 201-400 3: 401-750		1 per 150 <sup>12</sup>
Office or public buildings – for employee use	Male 1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Female 1: 1-15 3: 16-35 4: 36-55	Male 0: 1-9 1: 10-50 Add one fixture for each additional 50 males.	Male 1 per 40	Female 1 per 40		
Penal institutions – for employee use	Male 1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Female 1: 1-15 3: 16-35 4: 36-55	Male 0: 1-9 1: 10-50 Add one fixture for each additional 50 males.	Male 1 per 40	Female 1 per 40		1 per 150 <sup>12</sup>
Penal institutions – for prison use							
Cell	1 per cell		Male 1 per exercise room	1 per cell	1 per exercise room		1 per cell block floor
Exercise room	1 per exercise room						1 per exercise room
Public or professional offices <sup>15</sup>	Same as Office or Public Buildings for employee use <sup>15</sup>		Same as Office or Public Buildings for employee use <sup>15</sup>	Same as Office or Public Buildings for employee use <sup>15</sup>			Same as Office or Public Buildings for employee use <sup>15</sup>
Restaurants, pubs, and lounges <sup>11,15,16</sup>	Male 1: 1-50 2: 51-150 3: 151-300 Over 300, add 1 fixture for each additional 200 persons.	Female 1: 1-50 2: 51-150 4: 151-300	Male 1: 1-150 Over 150, add 1 fixture for each additional 150 males.	Male 1: 1-150 2: 151-200 3: 201-400 Over 400, add 1 fixture for each additional 400 persons.	Female 1: 1-150 2: 151-200 3: 201-400		
Retail or Wholesale Stores	Male 1:1-100 2:101-200 3:201-400 Over 400, add one fixture for each additional 500 males and one for each 150 females	Female 1:1-25 2:26-100 4:101-200 6:201-300 8: 301-400	Male 0:0-25 1:26-100 2:101-200 3:201-400 4:401-600 Over 600, add one fixture for each additional 300 males	One for each two water closets			0: 1-30 <sup>17</sup> 1:31-150 One additional drinking fountain for each 150 persons thereafter
Schools – for staff use All schools	Male 1: 1-15 2: 16-35 3: 36-55 Over 55, add 1 fixture for each additional 40 persons.	Female 1: 1-15 2: 16-35 3: 36-55	Male 1 per 50	Male 1 per 40	Female 1 per 40		
Schools – for student use Nursery	Male 1: 1-20 2: 21-50 Over 50, add 1 fixture for each additional 50 persons.	Female 1: 1-20 2: 21-50		Male 1: 1-25 2: 26-50 Over 50, add 1 fixture for each additional 50 persons.	Female 1: 1-25 2: 26-50		1 per 150 <sup>12</sup>
Elementary	Male 1 per 30	Female 1 per 25	Male 1 per 75	Male 1 per 35	Female 1 per 35		1 per 150 <sup>12</sup>
Secondary	Male 1 per 40	Female 1 per 30	Male 1 per 35	Male 1 per 40	Female 1 per 40		1 per 150 <sup>12</sup>
Others (colleges, universities, adult centers, etc.)	Male 1 per 40	Female 1 per 30	Male 1 per 35	Male 1 per 40	Female 1 per 40		1 per 150 <sup>12</sup>
Worship places educational and activities Unit	Male 1 per 150	Female 1 per 75	Male 1 per 150	1 per 2 water closets			1 per 150 <sup>12</sup>
Worship places principal assembly place	Male 1 per 150	Female 1 per 75	Male 1 per 150	1 per 2 water closets			1 per 150 <sup>12</sup>