

## **Errata for 2009 Uniform Plumbing Code – 6th Printing**

The following is a list of changes that we found after the sixth printing of the 2009 Uniform Plumbing Code. These changes may or may not apply to your code book. However, we do encourage you to check your code book with this list to ensure that all the changes are updated. Thank you.

### Chapter 5

**Section 507.2.2** Add extraction from NFPA 54:9.3.2.2(3) to Section 507.2.2.

#### **507.2.2 Known Air Infiltration Rate Method.**

Where the air infiltration rate of a structure is known, the minimum required volume shall be determined as follows [NFPA 54:9.3.2.2]:

- (1) No change
- (2) No change
- (3) For purposes of this calculation, an infiltration rate greater than 0.60 ACH shall not be used in the equations. [NFPA 54:9.3.2.2(3)]